

# Result Summary Report

Program:

Date Range:

Water Utility:

Supply System:

Drinking Water Monitoring

01-07-2023 - 30-06-2024

Yenda GT02

Barcode:

Analysis Type:

Characteristics:

Sample Types:

All

All

All

All

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	52	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.5556	1.5700	0.4073	0.82	2.63	52	0	2.35	0.91	100.00
	pH	6.5 - 8.5		7.4492	7.4500	0.1341	7.2	7.99	52	0	7.62	7.21	100.00
	Temperature	30.0000	C	19.9154	20.1500	4.0321	13.1	26.1	52	0	25.8	13.7	100.00
	Total Chlorine	5.0000	mg/L	1.7187	1.7100	0.5079	0.25	2.86	52	0	2.73	0.98	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	52	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2310	0.1900	0.2628	0.13	2.06	52	0	0.31	0.13	100.00