

# Result Summary Report

Program: **Drinking Water Monitoring Program**

Date Range: **01-06-2024 - 30-06-2024**

Water Utility:

Supply System: **Yenda GT02**

Barcode: All

Analysis Type: All

Characteristics: All

Sample Types: All

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	1.4075	1.3650	0.1261	1.31	1.59	4	0	1.59	1.31	100.00
	pH	6.5 - 8.5		7.5450	7.5350	0.0580	7.49	7.62	4	0	7.62	7.49	100.00
	Temperature	30.0000	C	14.2500	14.2500	1.0786	13.1	15.4	4	0	15.4	13.1	100.00
	Total Chlorine	5.0000	mg/L	1.6450	1.6250	0.1572	1.5	1.83	4	0	1.83	1.5	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2325	0.2350	0.0435	0.19	0.27	4	0	0.27	0.19	100.00